



dan@legacy-ce.com

508-376-8883(o)

508-868-8353(c)

730 Main Street

Suite 2C

Millis, MA 02054

October 23, 2019

Planning & Economic Development Board

Town Offices

155 Village Street

Medway, MA 02053

Ref: William Wallace Village
Special Permit and Site Plan Review

Dear Members of the Board:

Please find enclosed the following;

- Two full-size and one 11x17 copies of a revised site plan; and
- One copy of a revised stormwater report.

In order to address concerns expressed by the DPW about the front stormwater infiltration field, the outlet configuration was redesigned. We have reverted back to a small level spreader that will discharge small amounts of flow across the front landscape area, much as the site currently discharges runoff towards Village Street.

In addition, the following minor changes were made:

- ✓ The hydrant detail was revised to specify red paint per the Medway DPW regulations; and
- ✓ A registry recording block was added. It will be filled out on the final endorsement plans.

Do not hesitate to contact me if you have any questions or comments.

Yours Truly,

LEGACY ENGINEERING LLC

Daniel J. Merrikin, P.E.

President

cc: Conservation Commission